


# City of Lawrence

## Measurement & Verification Report

# Year 1 Savings

March 2018 through February 2019







# EXECUTIVE SUMMARY REPORT



#### **ENERGY PERFORMANCE CONTRACT 1-YEAR SUMMARY: THE CITY OF LAWRENCE**

In 2018, the City of Lawrence completed an Energy Performance Contract with Willdan Group Inc. (Willdan). The City of Lawrence was able to complete over \$12 million in capital upgrades, funded by Green Bonds. By leveraging energy savings, this project funded deferred maintenance needs in a cash-neutral manner.

#### PROJECT HIGHLIGHTS OF THE WORK IMPLEMENTED BY WILLDAN INCLUDED:

- Upgraded lighting to LED in 40 City buildings
- Upgraded sports field lighting to LED at highprofile sports complexes and athletic fields
- Upgraded outdoor lighting in all City parks
- Installed 100kW solar PV array at Fire Station No. 5
- Replaced Indoor Aquatic Center equipment to resolve humidity and indoor air quality issues
- Replaced boilers and chillers at multiple City facilities
- Replaced packaged rooftop units and split systems across numerous city facilities

- Replaced windows at City Hall
- Replaced roofs on three City buildings
- Upgraded antiquated controls city-wide
- Installed web-based thermostats in city offices and buildings
- Installed fresh air ventilation with ionic air cleaning at the Prairie Park Nature Center
- Performed weatherization sealing in 25 City buildings.

As a part of the energy savings contract, Willdan is responsible for measuring and verifying the project's energy savings over the next several years. Recently, the City of Lawrence was given the Year 1 Measurement and Verification (M&V) Report for the energy project.

As the report demonstrated, significant energy and maintenance cost savings were achieved throughout the City of Lawrence facilities in Year 1 of the M&V period. In Year 1, the City of Lawrence exceeded the savings guarantee, saving over \$550,000 annually. The total of all savings during the Year 1 reporting period was \$551,864 which was comprised of \$424,159 in electric and fuel savings and \$127,704 in maintenance savings.

The savings in Year 1 included almost 4,000 MWh (Mega-Watt Hours) of electrical consumption, and over 50,000 therms of natural gas. The electric and fuel savings in Year 1 from the City of Lawrence's project are equivalent to:

#### The Greenhouse Gas Emission from:

Miles driven by an average passenger vehicle



**Co2 Emissions From:**Pounds of coal burned



3,336,526

Carbon Sequestered By: An Acre of U.S. forests in one year



3,592

# TABLE OF CONTENTS

Project Summary	1
Savings Details	2
Overall Electrical Performance	2
Overall Gas Performance	3
Community Health Building Electrical Performance	4
Community Health Building Fuel Performance	5
Indoor Aquatic Center Electrical Performance	6
Indoor Aquatic Center Fuel Performance	7
Library Electrical Performance	
Airport Terminal Electrical Performance	9
Airport Terminal Fuel Performance	. 10
Fire/Med #5 Electrical Performance	11
Fire/Med #5 Fuel Performance	. 12
Fire/Med #4 Electrical Performance	13
Fire/Med #4 Fuel Performance	
Fire/Med #3 Electrical Performance	
Fire/Med #3 Fuel Performance	
Fire/Med #2 Electrical Performance	
Fire/Med #2 Fuel Performance	
Fire and Rescue Training Electrical Performance	
Fire and Rescue Training Fuel Performance	
Parking/Animal Control/Transit Electrical Performance	
Parking/Animal Control/Transit Fuel Performance	
Lawrence Arts Center Electrical Performance	
Lawrence Arts Center Fuel Performance	
City Hall Electrical Performance	
City Hall Fuel Performance	
East Lawrence Rec Center Electrical Performance	
East Lawrence Rec Center Fuel Performance	
Prairie Park Nature Center Electrical Performance	
Prairie Park Nature Center Fuel Performance	
Vehicle Maintenance Garage Electrical Performance	
Vehicle Maintenance Garage Fuel Performance	
Community Building Electrical Performance	
Community Building Fuel Performance	
Holcom Park Rec Center Electrical Performance	
Holcom Park Rec Center Fuel Performance	
Appendix	37

# **Project Summary**

Willdan Peformance Engineering is pleased to provide you with this report demonstrating the level of savings achieved during the Measurement and Verification Phase from March 2018 through February 2019 as a result of the energy conservation upgrades project. As this report demonstrates, significant energy and maintenance cost savings were achieved throughout your facilities. The total of all savings during the reporting period was \$551,864 which was comprised of \$205,577 in Option C Electric Savings, \$40,508 in Option C Fuel Savings, \$166,406 in Option A Electric Savings, \$11,668 in Stipulated Electric/Fuel Savings, and \$127,704 in Stipulated Maintenance Savings; the total was \$3,845 more than the guarantee savings of \$548,019. 'Facilty Improvements' are provided in the margins for each building; noting that 'Bonus Improvements' were implemented at Willdan's expense (i.e. no cost to the City).



Sincerely.

Kevin Player

Measurement & Verification Professional


## \$1,000,000 \$1,000,000 \$800,000 \$400,000 \$200,000 \$0 Adj Baseline Actual Cost

**Utility Cost** 

## Project Savings Performance Summary

The chart below tracks project savings over time. The blue line represents the guaranteed contract savings while the yellow line represents the actual savings achieved.

## Overall Project Cumulative Cost Savings







# Savings Details

## **Overall Electrical Performance**


The following graphs illustrate the electrical performance for all facilities during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.









## Overall Fuel Performance





The following graphs illustrate the fuel performance for all facilities during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.





The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.










## Community Health Building Electrical Performance


The following graphs illustrate the electrical performance for the Community Health Building during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.







The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- \* New Air-cooled chiller.
- \* New Air handler filtration.
- \* New DDC controls with updated sequences,
- \* New roof,
- \* New LED lighting




## Community Health Building Fuel Performance




The following graphs illustrate the fuel performance for the Community Health Building during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




- \* New heating water boilers,
- \* New Air handler filtration,
- \* New DDC controls with updated sequences.
- \* New roof







## Indoor Aquatic Center Electrical Performance


The following graphs illustrate the electrical performance for the Indoor Aquatic Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.







The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- \* 2 New dehumidification units,
- \* New low-capture exhaust systems.
- New pool pump variable frequency drives,
- New VAV air handler condensing unit,
- New supplemental electric heat,
- \* Updated sequences,
- \* LED lighting




## Indoor Aquatic Center Fuel Performance



The following graphs illustrate the fuel performance for the Indoor Aquatic Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




- \* 2 New dehumidification units,
- \* New pool heating boilers,
- \* New pool pump variable frequency drives,
- \* Updated sequences







## Library Electrical Performance


The following graphs illustrate the electrical performance for the Library during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.







- New CO2 sensors & updated sequences for demand controlled ventilation,
- \* LED lighting




## Airport Terminal Electrical Performance


The following graphs illustrate the electrical performance for the Airport Terminal during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.







The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.







- New AC split systems,
- \* New internet-based thermostats,
- \* LED lighting




## Airport Terminal Fuel Performance




The following graphs illustrate the fuel performance for the Airport Terminal during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- \* New gas furnaces,
- \* New internet-based thermostats







## Fire/Med #5 Electrical Performance


The following graphs illustrate the electrical performance for the Fire/Med #5 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





#### Facility Improvements:

- \* New 100 kW solar PV array,
- \* New DDC control system with updated sequences,
- LED lighting

#### Bonus Improvements:


 Rebalance register airflows to improve comfort




## Fire/Med #5 Fuel Performance





The following graphs illustrate the fuel performance for the Fire/Med #5 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





New DDC control system with updated sequences


#### Bonus Improvements:







## Fire/Med #4 Electrical Performance


The following graphs illustrate the electrical performance for the Fire/Med #4 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





#### Facility Improvements:

- \* New DDC control system with updated sequences,
- \* LED lighting


#### Bonus Improvements:




## Fire/Med #4 Fuel Performance



The following graphs illustrate the fuel performance for the Fire/Med #4 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





New DDC control system with updated sequences


#### Bonus Improvements:







## Fire/Med #3 Electrical Performance


The following graphs illustrate the electrical performance for the Fire/Med #3 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






#### Facility Improvements:

- \* New packaged heating & cooling roof-top units,
- \* New DDC control system with updated sequences,
- \* New roof,
- \* LED lighting


#### Bonus Improvements:




## Fire/Med #3 Fuel Performance




The following graphs illustrate the fuel performance for the Fire/Med #3 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.





The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




#### Facility Improvements:

- \* New packaged heating & cooling roof-top units.
- \* New DDC control system with updated sequences,
- \* New roof

#### Bonus Improvements:

\* Rebalance airflows to improve comfort





□Utility Cost Savings ■Utility Cost




## Fire/Med #2 Electrical Performance


The following graphs illustrate the electrical performance for the Fire/Med #2 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






#### Facility Improvements:

- \* New packaged heating & cooling roof-top units,
- \* New internet-based thermostats.
- \* LED lighting


#### Bonus Improvements:




## Fire/Med #2 Fuel Performance





The following graphs illustrate the fuel performance for the Fire/Med #2 during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





- \* New packaged heating & cooling roof-top units,
- \* New internet-based thermostats


#### Bonus Improvements:







## Fire and Rescue Training Electrical Performance


The following graphs illustrate the electrical performance for the Fire and Rescue Training during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






Facility Improvements:

\* New internet-based thermostats


\* LED lighting




## Fire and Rescue Training Fuel Performance




The following graphs illustrate the fuel performance for the Fire and Rescue Training during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




Facility Improvements:
\* New internet-based thermostats







## Parking/Animal Control/Transit Electrical Performance


The following graphs illustrate the electrical performance for the Parking/Animal Control/Transit during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- \* New packaged heating & cooling units (replaced electric heat with gas heat),
- \* New internet-based thermostats,
- \* LED lighting




## Parking/Animal Control/Transit Fuel Performance




The following graphs illustrate the fuel performance for the Parking/Animal Control/Transit during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




- New packaged heating & cooling units (replaced electric heat with gas heat),
- New internet-based thermostats







## Lawrence Arts Center Electrical Performance


The following graphs illustrate the electrical performance for the Lawrence Arts Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.







The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- New air-cooled chiller,
- \* New DDC control system with updated sequences,
- \* LED lighting (except theatre performance lights)




## Lawrence Arts Center Fuel Performance




The following graphs illustrate the fuel performance for the Lawrence Arts Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.



Facility Improvements:


\* New DDC controls with updated sequences







## City Hall Electrical Performance


The following graphs illustrate the electrical performance for the City Hall during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.







The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.







- \* New supplemental electric heating in entries,
- Updated control sequences,
- \* New windows,
- \* LED lighting




## City Hall Fuel Performance



The following graphs illustrate the fuel performance for the City Hall during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.



#### Facility Improvements:

- \* New supplemental electric heating in entries,
- \* Updated control sequences,
- New windows





□ Utility Cost Savings ■ Utility Cost




## East Lawrence Rec Center Electrical Performance


The following graphs illustrate the electrical performance for the East Lawrence Rec Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.







The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.







- New packaged heating & cooling rooftop units (except W. side)
- \* Updated control sequences,
- \* LED lighting




## East Lawrence Rec Center Fuel Performance




The following graphs illustrate the fuel performance for the East Lawrence Rec Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




- \* New packaged heating & cooling rooftop units (except W. side)
- \* Updated control sequences







## Prairie Park Nature Center Electrical Performance


The following graphs illustrate the electrical performance for the Prairie Park Nature Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





#### Facility Improvements:


- \* New AC split systems,
- New ventilation system,
- \* New DDC control system with updated sequences,
- LED lighting

#### **Bonus Improvements:**


\* New bipolar ionization cleaner on 3 split systems.




## Prairie Park Nature Center Fuel Performance




The following graphs illustrate the fuel performance for the Prairie Park Nature Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.





The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- \* New gas furnaces.
- New ventilation system,
- \* New DDC control system with updated sequences

#### Bonus Improvements:


\* New bipolar ionization cleaner on 3 furnaces.







## Vehicle Maintenance Garage Electrical Performance


The following graphs illustrate the electrical performance for the Vehicle Maintenance Garage during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.







- New AC ductless mini-split for Server Room,
- \* Internet-based thermostats,
- \* LED lighting




## Vehicle Maintenance Garage Fuel Performance





The following graphs illustrate the fuel performance for the Vehicle Maintenance Garage during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.












## Community Building Electrical Performance


The following graphs illustrate the electrical performance for the Community Building during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.






- \* New packaged heating & cooling rooftop units (except RTU-11),
- \* Updated control sequences,
- \* New roof
- \* LED lighting




# Community Building Fuel Performance




The following graphs illustrate the fuel performance for the Community Building during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.






The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.



### Facility Improvements:


- \* New packaged heating & cooling rooftop units (except RTU-11),
- \* Updated control sequences
- \* New roof







# Holcom Park Rec Center Electrical Performance


The following graphs illustrate the electrical performance for the Holcom Park Rec Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in electrical usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated electric savings.








The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.





#### Facility Improvements:


- New packaged heating & cooling rooftop units for Gym,
- New gas duct heaters for air handlers (remove hydronic heating),
- \* Updated control sequences,
- \* LED lighting

#### Bonus Improvements:


\* Rebalance airflows to improve comfort




# Holcom Park Rec Center Fuel Performance




The following graphs illustrate the fuel performance for the Holcom Park Rec Center during the measurement and verification period. The first graph below illustrates the weather adjustments and savings that occurred in fuel usage. The blue bar represents the baseline, the green bar represents the adjustments made to the baseline based on actual weather, and the yellow bar is the current usage. The difference between the blue and green bars is the savings (or loss) due to weather effects, and the difference between the green and yellow bars is the calculated fuel savings.





The graph below illustrates the monthly cost savings achieved through the project. The white bar represents savings, and the blue bar represents the new monthly costs.




## Facility Improvements:

- New packaged heating & cooling rooftop units for Gym,
- \* New gas duct heaters for air handlers (remove hydronics).
- \* Updated control sequences

### Bonus Improvements:

\* Retro-commission to improve comfort





# **Appendix**



# Overall Project Performance Summary

The cumulative energy savings performance across the Lawrence city-wide energy conservation project met the project savings guarantee, exceeding net expected savings by \$3,845 in the first year of Measurement and Verification. While this is a successful overall project result, some individual buildings performed better than individual facility model estimates, and some buildings performed worse than initial model estimates. Ultimately, more City of Lawrence buildings exceeded energy savings expectations, which offset poorer performing buildings.

Willdan recognizes that despite the overall project success, individual building performance issues can create a utility budgeting challenge, specifically for the poorer performing Indoor Aquatic Center (IAC). Willdan is committed to working with the City of Lawrence to help the City understand why this building did not perform as expected, as well as identify areas for improved function and reporting related to energy savings.

# Indoor Aquatic Center - Building Performance

The Indoor Aquatic Center has not performed as well as expected during the Measurement and Verification period. As shown in previous sections of this report, both gas and electric savings are lower than predicted. Several issues contributed to this outcome, including project components that were not fully executed. A brief description of each issue and its impact is shown below.

## Unoccupied Pool Turndown - Not Executed

This measure has had the most impact on the expected savings. During construction, Willdan installed variable-speed drives for the pool circulation pumps. The intent was to reduce the amount of water pumped at night when the pools are closed. Building codes require a minimum amount of pumped water to travel through the filtration system. These same codes allow for a reduction in pumped water when the pool is unoccupied. The planned pumping reduction saves both electricity and heat.

The pool pumps are in an underground vault below the mechanical room. The chemical treatment system is on the first level, in the mechanical room. To activate the chemical system, a portion of the circulated pool water is diverted to the chemical treatment system. Because the diverted water must move vertically upward to reach the chemical treatment system, extra pressure, known as "head", is required. The existing piping system uses a manual reducing valve to provide necessary head in the diversion loop. When the pool water circulation pumps are slowed down, a manual adjustment of the reducing valve would be required to maintain enough head for the chemical treatment loop.


The manual reducing valve for artificial flow resistance is contrary to recommended design. A better design would be the addition of a circulation pump that maintains required head without introducing artificial restrictions. If an additional circulation pump is installed for the chemical treatment system, the large pool circulation pumps can be turned down at night to achieve the expected energy savings.

### Leisure Pool Dehumidification Unit (DHU) - Consumes More than Expected

The Leisure Pool DHU was replaced as a separate project just prior to the Willdan construction project. The new DHU uses considerably more gas and electricity than the original unit that it replaced. The increase in electrical consumption can be seen in the summer months of 2017 in the graph below. This



increase was not considered in the baseline calculations (2014-2015) used to determine cost savings. The extra utility costs incurred from the new Leisure Pool DHU continue to contribute to the overall utility costs of the Indoor Aquatic Center.



## Pool Flow Meters - Not Accurate During IGA

During the Preliminary Analysis, Willdan engineers examined the existing flow meters for the pool circulation loops. They discovered that the pool circulation flows were higher than the design flow, resulting in wasted electrical energy. During the construction phase of the project, Willdan discovered that the circulation flow meters gave inaccurate readings. The actual pool circulation flows were at or lower than design flows. The circulation flow could not be lowered further, eliminating the potential savings.

#### Summary

The unexpected variations to the Willdan design and energy calculations have changed the expected utility costs of the Indoor Aquatic Center. Willdan continues to monitor the IAC building performance and can make further recommendations for energy reduction if the City of Lawrence would like to explore potential opportunities. While net project savings city-wide offset the poorer than expected performance at the IAC, Willdan recognizes individual building performance still creates challenges, and we are committed to helping the City with continued documentation of building performance and savings to assist in utility budget allocations, etc.

# **Utility Rate Adjustment**

The utility rates were adjusted for the current year's CPI according to Schedule C, Section 7 of the contract.

Table 1 - Utility Rates used for determining Actual Energy Savings

Utility Rate	Program Year	Electric Rate						
		\$ 0.0470 / kWh (Jun – Sept)						
Westar MGS	0	\$ 0.0390 / kWh (all other months)						
		\$ 22.22 / kW (all months)						
		\$ 0.0850 / kWh (all months)						
Westar SGS	0	\$ 8.47 / kW (Jun – Sept)						
		\$ 5.38 / kW (all other months)						
Natural Gas (Low Rate)	0	\$ 0.70 / Therm						
Natural Gas (Medium Rate)	0	\$ 0.85 / Therm						
Natural Gas (High Rate)	0	\$ 1.00 / Therm						
All Rates	Future Years	Year zero rate adjusted for current year's CPI or						
All Kules	roioie redis	future year's actual rate, whichever is greater.						

The current year's CPI was determined using the CPI Table for the Mid-Atlantic region on the U.S. Bureau of Labor Statistics' website:

https://www.bls.gov/regions/mid-atlantic/data/consumerpriceindexhistorical\_us\_table.htm

The CPI for March 2017 was used for the Baseline (year zero) CPI since the Contract Start Date was 2/28/2017. The average CPI was used for the Year 1 Performance Period (future year) CPI of March 2018 to February 2019 as follows:

CPI for 3/2017 = 243.801Avg. CPI for 3/2018 to 2/2019 = 251.543

Rate adjustment =  $(251.543 - 243.801) / 243.801 = \underline{0.0318}$ 

### New Rates:

Westar MGS	\$0.0485 / kWh (June - Sept) \$0.0402 / kWh (all other months) \$22.926 / kW (all months)
Westar SGS	\$0.0877 / kWh (all months) \$8.739 / kW (June – Sept) \$5.551 / kW (all other months)
Natural Gas (Low Rate)	\$0.722 / Therm
Natural Gas (Medium Rate)	\$0.877 / Therm
Natural Gas (High Rate)	\$1.032 / Therm

# Baseline Energy Adjustments – Not included in Savings

The following conditions were identified which according to the contract could be analyzed to determine adjustments to the Baseline Consumption. However, the adjustment associated with each item was not analyzed since Year 1 Savings produced enough savings to meet the guarantee. The items have been included in the Appendix for informational purposes to illustrate that additional savings beyond those reported could have been achieved.

#### East Lawrence Recreation Center

- 1) Unoccupied setpoints were found to be higher than the contract Unoccupied heating setpoint of 55F. All setpoints were higher than 60F, with some areas being overridden to 70-72F for Unoccupied heating setpoint.
  - a. Lobby/Weight Rm, & Gymnastics Rm had Unocc. Heat Setpoint set to 68F.
  - b. RTU-1, & Party/Conference Rm had Unocc. Heat Setpoint set to 70F.

#### Holcom Park Recreation Center

- 1) Unoccupied setpoints were found to be higher than the contract Unoccupied heating setpoint of 55F.
  - a. North Gym RTU, & South Gym RTU both had Unocc. Heat Setpoint overridden to 71F.
- 2) Improved comfort by adjusting Baseline Zone Differential setpoint from 3F to 1F, meaning previously a zone had to get 3F off setpoint before enabling heat or cool for that zone. Now, a zone will enable heat or cool when 1F off setpoint. This has provided vastly improved comfort in all areas of building, but will use more energy to achieve these comfort levels.

## City Setpoint Policy Changes updated January 1, 2018

Due to numerous comfort complaints at various buildings in both heating & cooling season, the city elected to update the setpoint policy on January 1, 2018 (Policy #121). Sections of the policy document have been included below:

All interior office workspaces within the City must have the following setpoints. During normal operating hours, thermostats shall have a setpoint between 68°F and 72°F during the heating

season and between 72°F and 76°F during the cooling season. The following spaces are exempt from the aforementioned standards:

- a) Pool spaces shall be kept at 2°F above pool water temperature setpoints;
- b) Gyms, community gathering areas, locker rooms and other changing areas shall be set for occupant comfort: and
- c) Residential sleeping quarters for first responders may have a setpoint between 70°F and 76°F during the cooling season.

The setpoints in red above conflict with the contractual setpoints in Schedule I, Section 1 of the contract (see below) and would result in increased energy consumption.

- 1) HVAC systems: ESCO will install systems capable of maintaining the following standards of comfort:
  - a) Occupied heating set points: 70°F
  - b) Occupied cooling set points: 74°F




# Option A Measurement & Verification of Electrical Energy Savings


The table below demonstrates the amount of savings achieved throughout all facilities in which Option A Savings was calculated. The table breaks down the essential measured parameters (kWh, kW) which were used to determine the achieved savings. Based on the analysis performed, the facilities saw a combined savings of \$166,406 this was \$27,651 more than the guaranteed savings of \$138,755. The graphs shown below the table are to illustrate the impact the energy saving measures have had on your facilities.


## City-Wide Building Lighting

	Pre-Project				Post-Project				Consumption	Annual		
	Consumption	Pre-Project	Pr	re-Project	Consumption	Post-Project	Р	ost-Project	Savings	Demand		Annual
Building Name	(kWh)	Demand (kW)		Cost (\$)	(kWh)	Demand (kW)		Cost (\$)	(kWh)	Savings (kW)	So	vings (\$)
Edgewood Park	24,847	68.1	\$	2,541	6,721	18.4	\$	789	18,126	49.7	\$	1,752
Hand Park	1,308	3.6	\$	266	301	8.0	\$	168	1,007	2.8	\$	97
Hobbs Park	8,681	36.1	\$	1,020	1,735	4.8	\$	307	6,946	31.3	\$	713
Holcomb Park	2,854	7.8	\$	415	587	1.6	\$	196	2,267	6.2	\$	219
Japanese Garden	1,586	4.3	\$	293	293	8.0	\$	168	1,293	3.5	\$	125
John Taylor Park	9,442	25.9	\$	1,052	2,307	6.3	\$	362	7,136	19.5	\$	690
Ludlam Park	2,178	6.0	\$	350	1,079	3.0	\$	244	1,099	3.0	\$	106
Lyons Park	6,672	18.3	\$	784	95	1.8	\$		6,577	16.5	\$	630
Prairie Park	6,174	16.9	\$	736	1,395	3.8	\$	274	4,778	13.1	\$	462
Rotary Arboretum	837	2.3	\$	220	117	0.3	\$	151	721	2.0	\$	70
South Park	35,107	96.2	\$	3,533	8,056	22.1	\$	918	27,051	74.1	\$	2,615
Walnut Park	2,615	7.2	\$	392	602	1.6	\$	198	2,014	5.5	\$	195
Youth Sports Complex	56,419	154.6	\$	5,593	15,728	43.1	\$	1,660	40,691	111.5	\$	3,933
Carnegie Buildings	16,291	77.9	\$	1,648	6,083	41.3	\$	744	10,208	36.6	\$	905
27th Street Maintenance	11,905	45.6	\$	1,199	6,270	24.0	\$	698	5,634	21.6	\$	502
Eagle Bend Clubhouse and	9,543	25.4	\$	977	4,285	11.6	\$	518	5,258	13.7	\$	458
New Hampshire Parking Go	349,215	530.4	\$	32,458	73,231	117.6	\$	6,938	275,984	412.8	\$	25,520
Union Pacific Depot	23,184	76.9	\$	2,284	6,593	26.3	\$	748	16,591	50.6	\$	1,536
Solid Waste	8,390	34.7	\$	855	4,512	18.5	\$	523	3,878	16.3	\$	331
South Park Admin	13,635	58.9	\$	1,316	5,360	33.3	\$	635	8,275	25.6	\$	681
Outdoor Aquatic Center	7,924	167.0	\$	1,394	3,135	58.4	\$	610	4,789	108.6	\$	784
Street Division Office + Re	27,164	122.8	\$	2,928	11,329	54.7	\$	1,314	15,835	68.1	\$	1,614
Riverfront Garage and Sur	103,482	196.3	\$	9,848	29,441	49.3	\$	2,879	74,041	147.0	\$	6,969
Salt Domes and Wakarusa	20,863	79.0	\$	2,229	5,160	17.4	\$	649	15,702	61.6	\$	1,580
North Lawrence Pump Star	13,012	38.7	\$	1,407	3,523	11.3	\$	485	9,488	27.4	\$	922
Parks and Rec Maintenance	13,103	50.2	\$	1,454	7,064	27.1	\$	848	6,039	23.1	\$	606
Downtown Parking Lots an	9,887	27.1	\$	1,095	2,924	8.0	\$	422	6,964	19.1	\$	673
Broken Arrow Park	8,325	22.8	\$	944	2,173	6.0	\$	349	6,152	16.9	\$	595
Brook Creek Park	4,186	11.5	\$	544	342	0.9	\$	172	3,844	10.5	\$	372
Burcham Park	864	2.4	\$	223	13	0.0	\$	141	851	2.3	\$	82

	Pre-Project				Post-Project				Consumption	Annual		
	Consumption	Pre-Project	Pr	re-Project	Consumption	Post-Project	P	ost-Project	Savings	Demand		Annual
Building Name	(kWh)	Demand (kW)	(	Cost (\$)	(kWh)	Demand (kW)		Cost (\$)	(kWh)	Savings (kW)	Sa	vings (\$)
Centennial Park	27,464	75.2	\$	2,794	6,684	18.3	\$	785	20,780	56.9	\$	2,008
Chief Jim McSwain Park	6,095	16.7	\$	728	1,551	4.3	\$	289	4,544	12.4	\$	439
Clinton Park	10,367	28.4	\$	1,141	2,115	5.8	\$	344	8,252	22.6	\$	798
Constant Park	4,656	12.8	\$	589	1,208	3.3	\$	256	3,448	9.4	\$	333
Dad Perry Park	11,904	32.6	\$	1,290	406	1.1	\$	179	11,498	31.5	\$	1,111
Deerfield Park	11,299	31.0	\$	1,231	2,691	7.4	\$	399	8,608	23.6	\$	832
Eagle Bend Golf	4,186	11.5	\$	544	558	1.5	\$	193	3,628	9.9	\$	351
Maintenance Building	41,709	154.4	\$	3,734	8,039	31.2	\$	837	33,670	123.1	\$	2,897
Community Hangar	44,731	122.6	\$	4,463	4,854	13.3	\$	609	39,876	109.3	\$	3,854
Hangar A	8,393	41.9	\$	1,014	1,585	5.8	\$	298	6,809	36.0	\$	717
Hangar B	7,353	74.2	\$	1,032	1,630	10.9	\$	318	5,723	63.3	\$	714
Hangar C	7,208	70.7	\$	1,008	1,552	9.0	\$	305	5,657	61.7	\$	702
Sports Pavilion	945,164	2,219.6	\$	90,250	378,107	887.9	\$	36,187	567,057	1,331.6	\$	54,062
Lawrence Street Lighting	380,067	1,041.3	\$	36,875	133,755	366.5	\$	13,067	246,313	674.8	\$	23,807
Totals	2,310,291	5,947.6	\$	226,692	755,189	1,980.6	\$	78,331	1,555,102	3,967.1	\$	148,361












# Sports Field Lighting

	Pre-Project				Post-Project				Annual	Annual		
	Consumption	Pre-Project	Pi	re-Project	Consumption	Post-Project	F	Post-Project	Consumption	Demand		Annual
Building Name	(kWh)	Demand (kW)		Cost (\$)	(kWh)	Demand (kW)		Cost (\$)	Savings (kWh)	Savings (kW)	Sa	vings (\$)
Broken Arrow Park	28,965	554.3	\$	4,537	17,233	329.8	\$	2,756	11,732	224.5	\$	1,781
Centennial Park	7,167	137.2	\$	1,228	4,420	84.6	\$	811	2,747	52.6	\$	417
Chief Jim McSwain Park	2,867	54.9	\$	575	1,768	33.8	\$	408	1,099	21.0	\$	167
Deerfield Park	4,300	82.3	\$	792	2,652	50.8	\$	542	1,648	31.5	\$	250
Holcomb Park	11,468	219.5	\$	1,881	7,073	135.4	\$	1,213	4,395	84.1	\$	667
Lyons Park	57,552	1,101.5	\$	8,878	46,656	892.9	\$	7,224	10,896	208.5	\$	1,655
Veterans Park	8,601	164.6	\$	1,445	5,304	101.5	\$	945	3,296	63.1	\$	501
Youth Sports Complex	383,249	6,851.0	\$	81,812	325,570	5,945.7	\$	70,718	57,679	905.3	\$	11,094
Holcom	-	-	\$	139	3,484	9.5	\$	476	(3,484)	(9.5)	\$	(337)
Clinton Softball Complex	2,405	6.6	\$	305	5,229	14.3	\$	500	(2,824)	(7.7)	\$	(195)
19th and Moodie	14,374	80.0	\$	1,665	5,932	41.0	\$	796	8,442	39.0	\$	869
Horticulture	9,836	46.7	\$	1,157	5,192	24.8	\$	677	4,644	21.9	\$	480
Oak Hill Cemetery	3,718	27.0	\$	555	935	5.6	\$	240	2,783	21.4	\$	315
15th Street Cemetery	6,572	38.0	\$	842	3,059	16.3	\$	462	3,513	21.7	\$	380
Totals	541,072	9,363.6	\$	105,812	434,506	7,686.1	\$	87,766	106,566	1,677.5	\$	18,045







# Option A Measurement & Calculated Savings Methodology

The following section explains how measurements were taken to determine the savings achieved.

- A. Savings calculated for Option A were determined by following the guidelines laid out in the International Performance Measurement & Verification Protocol Volume I. As prescribed by the instructions for Option A: Partially Measured Retrofit Isolation, the equipment affected by the energy conservation measures (ECM) was isolated and measured prior to the retrofit, and again post retrofit, to determine the impact of the ECM on the energy usage of the equipment.
- B. Sampling was conducted to obtain a 90% confidence and 20% precision according to Appendix B of the Federal Energy Management Program (FEMP) M&V Guidelines v4.0. The purpose of sampling is to monitor a representative sample of points rather than the entire population. The end result is to obtain reliable estimates within a specified precision and statistical confidence. The basic equation used in sample group sizing for 90% confidence and 20% precision is:

$$n = \frac{z^2 \cdot (C_v)^2}{(P)^2} = \frac{(1.645)^2 \cdot (0.5)^2}{(0.2)^2} = 16.91$$

Where, z = Z-statistic, 1.645 for 90% confidence; C<sub>v</sub> = Coefficient of Variance, 0.5; P = Precision, 20%.

For populations less than 500, the sample size should be modified using the finite population correction equation:

$$n^* = \frac{Nn}{n+N}$$

Where,  $n^*$  = sample size corrected for population size; n = sample size for infinite population; N = population size.

Furthermore, the sample size includes a 10% oversampling factor in case of data collection device failure or unexpectedly high data scatter.

$$n^* = \frac{Nn}{n+N} = \frac{(92)(16.91)}{16.91 + 92} = 14.28 \times 10\% = 15.7 = 16$$

- C. Pre-retrofit & post-retrofit measurements were taken at the various fixtures themselves, and then the average difference between the measurements was applied to all the fixtures in the sample set. The resulting savings was evaluated using the average occupancy, operations, and annual use to determine the total building energy savings.
- D. Pre-retrofit & post-retrofit annual usage was estimated for each fixture to calculate an annual consumption for each building.
- E. Pre-retrofit & post-retrofit annual consumption was then multiplied by the contractual energy rates to determine the annual energy costs.
- F. The pre-retrofit energy cost was then compared to the post-retrofit energy cost to determine the annual energy savings solely from the energy conservation measure.

# Solar PV Performance and Savings

The 100kW Solar PV array was installed on the roof of Fire/Medical #5 (1911 Stewart Ave.) in the summer of 2017. Since that time, this system has produced over 245,000 kWh of electrical power that would have been purchased from the electric utility.



Equivalent savings to 245,000 kWh includes the following:

## Greenhouse gas emissions from



## CO2 emissions from



## Carbon sequestered by

